

# Town of New Tecumseth 2022 Tottenham Drinking Water System Annual Report



Prepared in accordance with Section 11 of Ontario Regulation 170/03

For the Period of

**January 1 to December 31, 2022**

System Rating: Water Distribution and Supply Subsystem Class II

Drinking Water System No.: 220001085

Municipal DW License No.: 123-102, Issue No. 4

## Table of Contents

1.	INTRODUCTION .....	1
2.	REPORTING REQUIREMENTS (Section 11 - O.Reg.170/03) .....	1
2.1	Availability of Annual Water Report .....	1
2.2	Description of Drinking-Water System.....	1
2.3	Water Treatment Chemicals .....	1
2.4	Significant Expenses Incurred .....	2
2.5	Sampling and Testing .....	2
2.5.1	Schedule 7 - Operational Checks .....	2
2.5.2	Schedule 10 - Microbiological Sampling and Testing.....	2
2.5.3	Schedule 13 - Chemical Testing.....	2
2.5.4	Schedule 15.1 – Lead.....	2
2.5.5	Schedule 16 – Reporting of Adverse Test Results and Other Problem and .....	3
	Schedule 17 – Corrective Actions .....	3
2.6	Municipal Drinking Water Licence (MDWL) No. 123-102 Requirement .....	3

## Tables

### Schedule 7 Operational Testing

Table 1 – Summary of Raw Samples – Turbidity

Table 1.1 – Summary of Treated and Distribution Samples – Free Chlorine

### Schedule 10 Microbiological Testing

Table 2 – Summary of Treated, Raw and Distribution System Samples

### Schedule 13 Chemical Testing (HAAs, Nitrate and Nitrite)

Table 3 – Summary of Treated Water Samples – Inorganics

Table 3.1 – Summary of Treated Water Samples – Organics

Table 3.2 – Summary of Treated Water Samples – Haloacetic Acids

Table 3.3 – Summary of Treated Water Samples – Nitrite and Nitrate

Table 3.4 – Summary of Treated Water Samples – Sodium and Fluoride

### Schedule 15 Lead

Table 4 – Summary of Lead Samples

### Schedule 16 and 17

Table 5 – Details of Adverse Water Quality Incidents (AWQIs) and Corrective Actions

### Municipal Drinking Water Licence Requirement

Table 6.1 – Summary of Treated Water Samples – Iron

Table 6.2 – Summary of Treated Water Samples - Trihalomethanes

## 1. Introduction

In accordance with Ontario Regulation 170/03 (O.Reg.170/03): Drinking Water Systems, the Town of New Tecumseth has prepared this Annual Report which is required to be completed no later than February 28<sup>th</sup> of every year. This report covers the period of January 1<sup>st</sup> to December 31<sup>st</sup>, 2022, and the information provided complies with the reporting requirements outlined in Section 11 of O.Reg.170/03.

A summary of the Town of New Tecumseth's drinking water system description is outlined below:

Drinking-Water System Number:	220001085
Drinking-Water System Name:	Tottenham Water Supply System
Drinking-Water System Owner:	Corporation of the Town of New Tecumseth
Drinking-Water System Category:	Large Municipal Residential

## 2. Reporting Requirements (Section 11 - O.Reg.170/03)

### 2.1 Availability of Annual Water Report

This report has been prepared in accordance with Section 11 of Ontario Regulation 170/03 and is available, free of charge as follows:

- via the Town of New Tecumseth website (<http://newtecumseth.ca/>)
- via Public Request (email: [drinkingwater@newtecumseth.ca](mailto:drinkingwater@newtecumseth.ca) or phone 705-435-3900)

The users of water from the Town of New Tecumseth Tottenham Drinking Water System are advised through the Town of New Tecumseth's website and local newspaper when this report is available and how to obtain a copy.

### 2.2 Description of Drinking-Water System

The Tottenham Well Supply System consists of four groundwater production wells that are grouped into two general locations: Well #4 & #5 (Walkem Drive Wells) and Wells #6A & #7 (Coventry Park Wells). The water from these wells is conveyed through dedicated mains to the Mill Street Reservoir. The Reservoir has one active cell with a storage capacity of approximately 900 m<sup>3</sup>. The system includes a 4,500 m<sup>3</sup> elevated storage tank. The Tottenham Water System is supplemented with water from the Alliston Water Supply through a 300 mm diameter transmission main from Beeton McKelvey Reservoir.

The Mill Street Reservoir is the central location for the Supervisory Control and Data Acquisition (SCADA) system that provides various monitoring and control over the Tottenham Water System.

The Tottenham Water Supply system distributes treated water to approximately 9,708 consumers (based on data from the Planning Department). There are 3,110 service connections, comprising of residential, institutional, and industrial consumers. In addition, there are approximately 34.6 kilometers of water main and 283 hydrants.

### 2.3 Water Treatment Chemicals

The following water treatment chemicals were utilized during the reporting period:

- Sodium Hypochlorite (12%)
- Sodium Silicate

## 2.4 Significant Expenses Incurred

The following major expenses were incurred during the reporting period to install, or replace required equipment:

A brief summary and value of the expenses incurred, including those outlined above, are as follows:

Maintenance Activity	Costs Incurred (2022)
Flow Meter Calibration	\$2,001
Coventry Park Wells Fencing	\$19,000
Cleaning and Inspection of the Tottenham Water Tower	\$7,000
Completion and Commissioning of the Tottenham Transmission Main (total cost over three years)	\$16,000,000

## 2.5 Sampling and Testing

Drinking water samples were collected and tested in accordance with O.Reg. 170/03 and tested in accordance with O.Reg. 169/03.

### 2.5.1 Schedule 7 - Operational Checks

Operational checks including raw water turbidity, and free chlorine (treated and distribution) were conducted in accordance with Schedule 7 of O.Reg.170/03. The operational testing conducted during this reporting period are summarized in Table 1 of this report.

### 2.5.2 Schedule 10 - Microbiological Sampling and Testing

Microbiological testing on raw, treated and distribution water samples was conducted in accordance with Schedule 10-2, 10-3 and 10-4 of O.Reg.170/03. The microbiological testing and sampling conducted during this reporting period is summarized in Tables 2 of this report.

In addition to the required microbiological testing from O. Reg. 170/03 (i.e. Total Coliform and E. Coli) Tables 2.1 and 2.2, include bacteriological health-related parameter; Heterotrophic Plate Count (HPC). HPC is a useful operational tool for monitoring general bacteriological water quality throughout the treatment process and in the distribution system. HPC results are not an indicator of water safety and, as such, should not be used as an indicator of potential adverse human health effects.

### 2.5.3 Schedule 13 - Chemical Testing

Chemical testing for organic and inorganic parameters was conducted on treated water samples in accordance with Schedule 13, Sections 13.2 (Schedule 23), 13.4 (Schedule 24), 13.8 and 13.9. The latest 36-month and 60-month test results are summarized in Table 3 of this report.

Chemical testing for trihalomethanes (THMs), haloacetic acids (HAAs), and nitrate and nitrite was conducted quarterly in accordance with Schedule 13.6 and 13.7 of O.Reg 170/03 respectively. THM sampling is performed in the distribution system and nitrate and nitrites sampling is performed at the reservoir (treated samples). The latest test results are summarized in Table 3 (nitrate and nitrite) and in Table 5.1 (THMs) of this report.

### 2.5.4 Schedule 15.1 – Lead

Lead and Alkalinity samples are collected from several locations within the distribution system in accordance with O. Reg 170/03 Schedule 15.1. Lead samples are required to be done every three years and was completed in

2022. Alkalinity samples are required to be sampled between December 15<sup>th</sup> and April 15<sup>th</sup> and June 15<sup>th</sup> and October 15<sup>th</sup> every year. The latest test results are summarized in Table 4 of this report.

### **2.5.5 Schedule 16 – Reporting of Adverse Test Results and Other Problem and Schedule 17 – Corrective Actions**

Adverse water quality incidents (AWQI) were reported in accordance with Schedule 16 and corrective actions related to each incident were completed in accordance with Schedule 17. A summary of the AWQI's and associated corrective actions that occurred during this reporting period is included in Table 5 of this report.

## **2.6 Municipal Drinking Water Licence (MDWL) No. 123-102 Requirement**

In addition to the sampling and monitoring required under O.Reg 170/03, Schedule C: System Specific Conditions for the Tottenham Distribution System requires sampling, testing and monitoring for THMs on a monthly basis commencing July 2016 and Iron sampling on a quarterly basis also commencing July 2016. The latest test results required under the MDWL are included in Table 6.1 and 6.2.

# Tables

**Table 1 - Schedule 7 Operational Checks  
Summary of Raw Samples – Turbidity**

Sampling Location	Number of Samples	NTU	
		Min	Max
<b>Raw Water Turbidity</b>			
Well #4	12	0.16	0.67
Well #5	12	0.14	0.69
Well #6A	12	0.26	0.95
Well #7	12	0.15	0.69

**Table 1.1 - Schedule 7 Operational Checks  
Summary of Treated and Distribution Samples – Free Chlorine**

Sampling Location	Number of Samples	mg/L (min/max)
<b>Treated Water Free Chlorine</b>		
Mill Street Reservoir	*8760	0.63/1.78
<b>Distribution Water Free Chlorine</b>		
Walkem Drive	*8760	0.69/2.20

**Notes:**

- \*8760 represents Continuous Monitoring
- Low chlorine residuals that are recorded by continuous monitoring equipment during equipment malfunctions or power outages are not considered to be an adverse event. These incidents are responded to by operations staff for resolution. Also, the value of 0.00 recorded by the continuous chlorine analyzer could be a result of equipment abnormality / SCADA issue / maintenance work or calibration.

**Table 2 - Schedule 10 Microbiological Sampling and Testing  
Summary of Treated and Distribution System Samples**

Source	Number of Samples	E.Coli (min/max)	Total Coliform (min/max)	HPC (min/max)
<b>Treated Water</b>				
Mill Street Reservoir	52	0/0	0/0	0/6
<b>Total Number of Treated Samples</b>				<b>52</b>
<b>Raw Water</b>				
Well #4	52	0/0	0/13	--
Well #5	52	0/0	0/0	--
Well #6A	52	0/0	0/0	--
Well #7	52	0/0	0/0	--
<b>Total Number of Raw Samples</b>				<b>208</b>
<b>Distribution System</b>				
Routine Sampling Points	341	0/0	0/0	0/88
Other (main breaks, new construction)	6	0/0	0/0	0/23
<b>Total Distribution Samples</b>				<b>347</b>

**Notes:**

**Table 3 - Schedule 13 Chemical Sampling and Testing  
Summary of Treated Water Samples – Inorganics**

Parameter	Sample Date (mm/dd/yr)	Result Value	Exceedance	Standard
<b>Mill Street Reservoir</b>				
Antimony	02/23/2021	0.9<MDL	No	6.0
Arsenic	02/23/2021	0.7	No	25
Barium	02/23/2021	129	No	1000
Boron	02/23/2021	67	No	5000
Cadmium	02/23/2021	0.003<MDL	No	5.0
Chromium	02/23/2021	0.44	No	50
Mercury	02/23/2021	0.01<MDL	No	1.0
Selenium	02/23/2021	0.04<MDL	No	10
Uranium	02/23/2021	0.015	No	20

**Notes:**

- Results expressed in ug/L
- MDL – Maximum Detection Limit Results expressed in ug/L

**Table 3.1 - Schedule 13 Chemical Sampling and Testing  
Summary of Treated Water Samples – Organics**

Parameter	Sample Date (mm/dd/yr)	Result Value	Exceedance	Standard
<b>Mill Street Reservoir</b>				
Alachlor	02/23/2021	0.02<MDL	No	5.0
Atrazine+N-dealkylated metabolites	02/23/2021	0.01<MDL	No	5.0
Azinphos-methyl	02/23/2021	0.05<MDL	No	20.0
Benzene	02/23/2021	0.32<MDL	No	5.0
Benzo(a)pyrene	02/23/2021	0.004<MDL	No	0.01
Bromoxynil	02/23/2021	0.33<MDL	No	5.0
Carbaryl	02/23/2021	0.05<MDL	No	90.0
Carbofuran	02/23/2021	0.01<MDL	No	90.0
Carbon Tetrachloride	02/23/2021	0.17<MDL	No	5.0
Chlorpyrifos	02/23/2021	0.02<MDL	No	90.0
Diazinon	02/23/2021	0.02<MDL	No	20.0
Dicamba	02/23/2021	0.20<MDL	No	120
1,2-Dichlorobenzene	02/23/2021	0.41<MDL	No	200
1,4-Dichlorobenzene	02/23/2021	0.36<MDL	No	5.0
1,2-dichloroethane	02/23/2021	0.35<MDL	No	5.0
1,1-Dichloroethylene (vinylidene chloride)	02/23/2021	0.33<MDL	No	14.0
Dichloromethane	02/23/2021	0.35<MDL	No	50.0
2,4-Dichlorophenol	02/23/2021	0.15<MDL	No	900
2,4-Dichlorophenoxy acetic acid (2,4-D)	02/23/2021	0.19<MDL	No	100
Diclofop-methyl	02/23/2021	0.40<MDL	No	9.0
Dimethoate	02/23/2021	0.06<MDL	No	20.0
Diquat	02/23/2021	1<MDL	No	70.0
Diuron	02/23/2021	0.03<MDL	No	150
Glyphosate	02/23/2021	1<MDL	No	280
Malathion	02/23/2021	0.02<MDL	No	190
MCPA	02/23/2021	0.12<MDL	No	100
Metolachlor	02/23/2021	0.01<MDL	No	50.0
Metribuzin	02/23/2021	0.02<MDL	No	80.0
Monochlorobenzene	02/23/2021	0.3<MDL	No	80.0
Paraquat	02/23/2021	1<MDL	No	10.0



**Table 3.1 - Schedule 13 Chemical Sampling and Testing  
Summary of Treated Water Samples – Organics**

Parameter	Sample Date (mm/dd/yr)	Result Value	Exceedance	Standard
<b>Mill Street Reservoir</b>				
Pentachlorophenol	02/23/2021	0.15<MDL	No	60.0
Phorate	02/23/2021	0.01<MDL	No	2.0
Picloram	02/23/2021	1<MDL	No	190
Polychlorinated Biphenyls (PCB)	02/23/2021	0.04<MDL	No	3.0
Prometryne	02/23/2021	0.03<MDL	No	1.0
Simazine	02/23/2021	0.01<MDL	No	10.0
Terbufos	02/23/2021	0.01<MDL	No	1.0
Tetrachloroethylene (perchloroethylene)	02/23/2021	0.35<MDL	No	30.0
2,3,4,6-Tetrachlorophenol	02/23/2021	0.20<MDL	No	100
Triallate	02/23/2021	0.01<MDL	No	230
Trichloroethylene	02/23/2021	0.44<MDL	No	5.0
2,4,6-Trichlorophenol	02/23/2021	0.25<MDL	No	5.0
Trifluralin	02/23/2021	0.02<MDL	No	45.0
Vinyl Chloride	02/23/2021	0.17<MDL	No	2.0

**Notes:**

- Results expressed in ug/L
- MDL – Maximum Detection Limit

**Table 3.2 - Schedule 13 Chemical Sampling and Testing  
Summary of Treated Water Samples – Haloacetic Acids**

Date	Location	HAA Results	HAA Running Annual Average	Exceedance	Standard
March 1, 2022	Pierce Place	17.9	16.3	No	80
June 7, 2022	Pierce Place	10.5			
September 13, 2022	Pierce Place	20.1			
December 20, 2022	Pierce Place	18.9			

**Notes:**

- Results expressed in µg/L

**Table 3.3 - Schedule 13 Chemical Sampling and Testing  
Summary of Treated Water Samples – Nitrite and Nitrate**

Parameter	Sample Date (mm/dd/yr)	Result Value	Exceedance	Standard
<b>Mill Street Reservoir</b>				
Nitrite	01/11/2022	0.003 <MDL	No	1.0
	04/12/2022	0.003 <MDL		
	07/12/2022	0.003 <MDL		
	10/11/2022	0.003 <MDL		
Nitrate	01/11/2022	0.055	No	10.0
	04/12/2022	0.053		
	07/12/2022	0.129		
	10/11/2022	0.147		

**Notes:**

- Results expressed in mg/L

**Table 3.4 - Schedule 13 Chemical Sampling and Testing  
Summary of Treated Water Samples – Sodium and Fluoride**

Parameter	Sample Date (mm/dd/yr)	Result Value	Exceedance	Standard
<b>Mill Street Reservoir</b>				
Sodium	10/11/2022	19.4	No	200*
Fluoride	10/29/2018	0.22	No	1.5

**Notes:**

- Results expressed in mg/L

\* The local Medical Officer of Health should be notified when the sodium concentration exceeds 20 mg/l so that this information may be communicated to local physicians for their use with patients on sodium restricted diets.

**Table 4 – Schedule 15.1 Lead  
Summary of Lead Samples**

Parameter	Sample Date (mm/dd/yr)	Number of Samples	Range of Results (min max)	Exceedance	Standard
Lead (Distribution System)	04/14/2020 10/13/2020	6	0.01 – 1.00 µg/l	No	10
Alkalinity (Distribution System)	04/12/2022 10/11/2022	6	143 - 221 (mg/l)	No	30 – 500*

**Notes:**

\*Aesthetic Objective under the Ontario Drinking Water Standards, Objectives and Guidelines

**Table 5 – Details of Adverse Water Quality Incidents (AWQIs) and Corrective Actions  
(Schedule 16 & 17)**

AWQI #	Incident Date (mm/dd/yr)	Location	Parameter	Result	Unit of Measure	Corrective Action Taken	Corrective Action Date (mm/dd/yr)
159456	08/02/2022	Distribution	Lead	18.2	µg/l	Sample taken from Hydrant as part of a study and the Hydrant was not flushed properly. Resampled twice with results less than 0.33 µg/l for both samples	08/17/2022

**Table 6.1 – Municipal Drinking Water License (MDWL) No. 123-102 Requirement  
Summary of Treated Water Samples - Iron**

Parameter	Location	Sample Date (mm/dd/yr)	Results (µg/l)
Iron	Mill Street Reservoir	01/11/2022	713
Iron	Pierce Place SS	03/01/2022	619
Iron	Mill Street Reservoir	04/12/2022	706
Iron	Pierce Place SS	06/07/2022	314
Iron	Mill Street Reservoir	07/12/2022	288
Iron	Pierce Place SS	09/13/2022	367
Iron	Mill Street Reservoir	10/11/2022	248
Iron	Pierce Place SS	10/11/2022	249
Iron	Pierce Place SS	12/20/2022	612

**Table 6.2 – Municipal Drinking Water Licence (MDWL) No. 123-102 Requirement  
Summary of Distribution Water Samples – Trihalomethanes**

Date	THM Results	Location	THM Quarterly Average	THM Running Annual Average	Exceedance	Standard
01/11/2022	88.0	Nolan Road	77.2			
01/11/2022	59.0	Water Tower				
01/11/2022	88.0	Pierce Place				
01/11/2022	88.0	Martin Trail				
01/11/2022	78.0	Dillane St E				
01/11/2022	57.0	78 Walkem				
02/17/2022	86.0	Nolan Road				
02/17/2022	64.0	Water Tower				
02/17/2022	86.0	Pierce Place				
02/17/2022	82.0	Martin Trail				
02/17/2022	71.0	Dillane St E				
02/17/2022	53.0	78 Walkem				
03/17/2022	77.0	Nolan Road				
03/17/2022	97.0	Water Tower				
03/17/2022	80.0	Pierce Place				
03/17/2022	80.0	Martin Trail				
03/17/2022	91.0	Dillane St E				
03/17/2022	64.0	78 Walkem				
04/12/2022	93.0	Nolan Road				
04/12/2022	69.0	Water Tower				
04/12/2022	86.0	Pierce Place				
04/12/2022	87.0	Martin Trail				
04/12/2022	114.0	Dillane St E				
04/12/2022	60.0	78 Walkem				
05/19/2022	72.0	Nolan Road				
05/19/2022	111.0	Water Tower				
05/19/2022	75.0	Pierce Place				
05/19/2022	73.0	Martin Trail				
05/19/2022	94.0	Dillane St E				
05/19/2022	48.0	78 Walkem				
06/06/2022	36.0	Nolan Road				
06/06/2022	60.0	Water Tower				
06/06/2022	30.0	Pierce Place				
06/06/2022	30.0	Martin Trail				
06/06/2022	49.0	Dillane St E				
06/06/2022	31.0	78 Walkem				
07/12/2022	40.0	Nolan Road	43.4			
07/12/2022	45.0	Water Tower				
07/12/2022	40.0	Pierce Place				
07/12/2022	36.0	Martin Trail				
07/12/2022	35.0	Dillane St E				
07/12/2022	48.0	78 Walkem				
08/16/2022	59.0	Nolan Road				
08/16/2022	55.0	Water Tower				
08/16/2022	43.0	Pierce Place				
08/16/2022	44.0	Martin Trail				
08/16/2022	51.0	Dillane St E				
08/16/2022	33.0	78 Walkem				
09/13/2022	42.0	Nolan Road				
09/13/2022	55.0	Water Tower				
09/13/2022	41.0	Pierce Place				
09/13/2022	40.0	Martin Trail				
09/13/2022	44.0	Dillane St E				
09/13/2022	30.0	78 Walkem				

**Table 6.2 – Municipal Drinking Water Licence (MDWL) No. 123-102 Requirement  
Summary of Distribution Water Samples – Trihalomethanes**

Date	THM Results	Location	THM Quarterly Average	THM Running Annual Average	Exceedance	Standard
10/11/2022	49.0	Nolan Road	44.3	58.1	No	100
10/11/2022	58.0	Water Tower				
10/11/2022	43.0	Pierce Place				
10/11/2022	40.0	Martin Trail				
10/11/2022	37.0	Dillane St E				
10/11/2022	60.0	78 Walkem				
11/15/2022	48.0	Nolan Road				
11/15/2022	62.0	Water Tower				
11/15/2022	47.0	Pierce Place				
11/15/2022	60.0	Martin Trail				
11/15/2022	45.0	Dillane St E				
11/15/2022	27.0	78 Walkem				
12/20/2022	37.0	Nolan Road				
12/20/2022	50.0	Water Tower				
12/20/2022	34.0	Pierce Place				
12/20/2022	44.0	Martin Trail				
12/20/2022	33.0	Dillane St E				
12/20/2022	24.0	78 Walkem				

**Notes:** - Results expressed in ug/L