New Tecumseth Drinking Water System

June 2026

Trihalomethane (THM) Testing for Second Quarter 2026

Date	Lilly Street	Pierce Place
April 8th	27.1 µg/l	40.5 µg/l

The Current Running Annual Average (RRA) is 51.5µg/l based on the last four (4) Quarters (July 2025 – June 2026). The Maximum Acceptable Concentration for THMs is 100 µg/l.

Haloacetic Acids (HAA) Testing for Second Quarter 2026

Date	Water Tower	Nolan Road
June 17th	11.9 µg/l	17.7 µg/l

The Current Running Annual Average (RRA) is 16.8 µg/l based on the last four (4) Quarters (April 2025 – March 2026). The Maximum Acceptable Concentration for HAAs is 80 µg/l.

Chemical Testing for the Second Quarter of 2026 - Sample Date April 8th

Parameter	Nitrite	Nitrate	Iron	Hardness
Parsons Reservoir	0.010< mg/l	0.230mg/l	<50µg/l	103mg/l
Well #1	0.010< mg/l	<0.020mg/l	331µg/l	164mg/l
Well #4	0.010< mg/l	<0.020mg/l	460µg/l	196mg/l
Well #5	0.010< mg/l	<0.020mg/l	114µg/l	167mg/l
Well #6	0.010< mg/l	<0.020mg/l	483µg/l	203mg/l
Well #7	0.010< mg/l	<0.020mg/l	517µg/l	233mg/l
Well #8	0.010< mg/l	<0.020mg/	193µg/l	153mg/l
Lilly Street	-	-	<50µg/l	97.7mg/l
Mill Street Reservoir	<0.010 mg/l	0.168 mg/l	224µg/l	119mg/l
Nolan Road	-	-	168µg/l	117mg/l

New Tecumseth Drinking Water System

June 2026

Distribution Microbiological Testing for June 2026

Date	June 3rd	June 10th	June 17th	June 24th
Location #1	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC
Location #2	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC
Location #3	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC
Location #4	0 EC, 1 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC
Location #5	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC
Location #6	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC
Location #7	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC
Location #8	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC
Location #9	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC
Location #10	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC
Location #11	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC
Location #12	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC

E.C. – Escherichia Coli, T.C. – Total Coliform

*Location #1-7 from the Alliston/Beeton Area

*Location #8-12 from the Tottenham Area