New Tecumseth Drinking Water System

July 2026

Trihalomethane (THM) Testing for Third Quarter 2026

Date	Lilly Street	Pierce Place
July 14th	42.9 µg/l	60.7 µg/l

The Current Running Annual Average (RRA) is 50.7µg/l based on the last four (4) Quarters (July 2025 – June 2026). The Maximum Acceptable Concentration for THMs is 100 µg/l.

Haloacetic Acids (HAA) Testing for Second Quarter 2026

Date	Water Tower	Nolan Road
June 17th	11.9 µg/l	17.7 µg/l

The Current Running Annual Average (RRA) is 16.8 µg/l based on the last four (4) Quarters (April 2025 – March 2026). The Maximum Acceptable Concentration for HAAs is 80 µg/l.

Chemical Testing for the Third Quarter of 2026 - Sample Date July 14th

Parameter	Nitrite	Nitrate	Iron	Hardness
Parsons Reservoir	0.010< mg/l	0.118mg/l	130µg/l	117mg/l
Well #1	0.010< mg/l	<0.020mg/l	312µg/l	156mg/l
Well #4	0.010< mg/l	<0.020mg/l	451µg/l	189mg/l
Well #5	0.010< mg/l	<0.020mg/l	169µg/l	161mg/l
Well #6	0.010< mg/l	<0.020mg/l	1970µg/l	195mg/l
Well #7	0.010< mg/l	<0.020mg/l	420µg/l	220mg/l
Well #8	0.010< mg/l	<0.020mg/	196µg/l	150mg/l
Lilly Street	-	-	<50µg/l	98.9mg/l
Mill Street Reservoir	<0.010 mg/l	0.160 mg/l	137µg/l	107mg/l
Nolan Road	-	-	1330µg/l	112mg/l

*Location #1-8 from the Alliston/Beeton Area

*Location #9-10 from the Tottenham Area

New Tecumseth Drinking Water System

July 2026

Distribution Microbiological Testing for July 2026

Date	July 2nd	July 8th	July 14th	July 22nd	July 29th
Location #1	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC
Location #2	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC
Location #3	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC
Location #4	0 EC, 1 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC
Location #5	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC
Location #6	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC
Location #7	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC
Location #8	0 EC, 0 TC	0 EC, 1 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC
Location #9	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC
Location #10	0 EC, 0 TC	0 EC, 1 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC
Location #11	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC
Location #12	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC

E.C. – Escherichia Coli, T.C. – Total Coliform

*Location #1-7 from the Alliston/Beeton Area

*Location #8-12 from the Tottenham Area